

IEC**IECEE**

®

TM

Ref. Certif. No.

JPTUV-139677

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Three Phase Power Distribution Unit
Name and address of the applicant	Shenzhen Century Cloud Core Technologies Limited F1-F5, B1 Complex Building, Gangtou Industrial Park, Yabian Community,, Shajing Town, Baoan District, Shenzhen, 518104 Guangdong, P.R. China
Name and address of the manufacturer	Shenzhen Century Cloud Core Technologies Limited F1-F5, B1 Complex Building, Gangtou Industrial Park, Yabian Community,, Shajing Town, Baoan District, Shenzhen, 518104 Guangdong, P.R. China
Name and address of the factory	Shenzhen Qunfang Technology Co., Ltd. 401, No.4, Huihao Industrial Park, 5th Industrial Area, Heshuikou Community, Matian Street, Guangming District, Shenzhen, 518132 Guangdong, P.R. China
Ratings and principal characteristics	Input: 346-480 Y/200-277 V AC, 3-phase, 50/60 Hz, 3P+N+PE, 100 A Max per phase Output: Refer to page 2
Trademark (if any)	ANTPDU
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	PW12V1
Additional information (if necessary may also be reported on page 2)	See test report
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22DVPO 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2022-09-22

Signature:

Paulus Hou

Additional information :

Continuation

Output: 200-277 V AC, single phase, 50/60 Hz

346-480 V AC, Three phase, 50/60 Hz

25 A Max per outlet, 100A Max per phase, Single outlet X1: 2A

Total 83kW max for all outlets